

CTS Certification and Testing Service, Inc.

41755 Elm Street, Suite 202
Murrieta, CA 92562
Tel: 951-894-6079 Fax: 951-894-6083

www.CleanroomTestCertification.com

CERTIFICATE OF CERTIFICATION

COMPANY Konicom, Inc. TEST DATE: December 30, 2016
ADDRESS 1819 J Street
Sacramento, CA 95811 DUE DATE: December 2017
CLEANROOM/S TESTED Production CER REQUESTOR: Bryan Wu

AIRBORNE PARTICULATE CLEANLINESS CLASS TESTING RESULTS :

| | <u>CLASS MET</u> | <u>MICRON</u> | <u>CONDITION</u> |
|-------------------------|--------------------|---------------------------|------------------|
| ROOM: <u>PRODUCTION</u> | <u>ISO CLASS 5</u> | <u>0.5, 1.0 & 5.0</u> | <u>At-Rest</u> |

TEST EQUIPMENT: Climet Model 750T CALIBRATION DUE DATE: November 30, 2017

CERTIFIED PER ISO 14644-1:2015(E) CLEANLINESS CLASSIFICATION

[Signature] Date: 1-18-2017
Signature of Approval
CTS Certification and Testing Service, Inc.