



**Certification and Testing Service, Inc.**

www.CleanroomTestCertification.com

41755 Elm Street, Suite 202

Murrieta, CA 92562

Tel: 951-894-6079 Fax: 951-894-6083

## CERTIFICATE OF CERTIFICATION

COMPANY Konicom, Inc. TEST DATE: October 05, 2018  
 ADDRESS 1819 J Street  
Sacramento, CA 95811 DUE DATE: October 2019  
 CLEANROOM/S TESTED Production CER REQUESTOR: Bryan Wu

### AIRBORNE PARTICULATE CLEANLINESS CLASS TESTING RESULTS :

|                         | <u>CLASS MET</u>   | <u>MICRON</u>             | <u>CONDITION</u> |
|-------------------------|--------------------|---------------------------|------------------|
| ROOM: <u>PRODUCTION</u> | <u>ISO CLASS 5</u> | <u>0.5, 1.0 &amp; 5.0</u> | <u>At-Rest</u>   |

TEST EQUIPMENT: Climet Model 750T

CALIBRATION DUE DATE: November 30, 2018

**CERTIFIED PER ISO 14644-1:1999(E) CLEANLINESS CLASSIFICATION**

Signature of Approval

Date: 10-19-18

CTS Certification and Testing Service, Inc.